





ZD0820



ZD0820

Installation Instructions:

All products must be installed by a suitably competent electrician giving consideration to their intended use and in accordance with the current edition of BS 7671 (IET Wiring Regulations).

The Electricity at Work Regulations and the Health and Safety at Work Act shall be complied with.

Only equipment and arrangements specified in Hager's technical documentation / catalogue shall be used.



Install in the horizontal plane only.

For guidance when making connections in a consumer unit electrical safety first / BEAMA document "Guidance for installers when making connections in consumer units" is available from hager.co.uk/63026.htm

Important notice:
To prevent potential overheating from loose connections the installer shall check connections are tight to the torque levels stated in these instructions prior to energising this board. This check should include factory made connections which may have loosened in transit.

Good workmanship and proper materials must be applied by the installer. The cable entry method shall, as far as reasonably practical, maintain the non-combustible arrangement of the enclosure. Account shall be taken of these instructions.

For guidance on RCD selection, AFDD selection and more, see the related BEAMA guide in our BEAMA guide web page - hager.co.uk/18thedition.



Design 10
Dimensions (mm)

	Enclosure Size						
	2	3	4	5	6	7	
Height	246	246	246	246	246	246	
Width	155	227	299	370	406	478	
Depth 1	83	83	83	83	83	83	
Depth 2	100	100	100	100	100	100	

Design 10 Dual Row
Dimensions (mm)

	Enclosure Size						
	3 (2)	4 (2)	5 (2)	6 (2)	7 (2)		
Height	486	486	486	486	486		
Width	227	299	370	406	478		
Depth 1	83	83	83	83	83		
Depth 2	100	100	100	100	100		

Boards with Square Knockouts

Number of Knockouts						
☐ Top Face 30 x 25	2	2	2	2	2	2
☐ Top Face 40 x 30	0	2	4	4	6	6
☐ Back 100 x 50	1	1	1	3	3	3
☐ Bottom Face 30 x 25	2	3	4	4	5	5

Number of Knockouts

Number of Knockouts						
2	2	2	2	2	2	2
2	4	4	4	6	6	6
2	2	6	6	6	6	6
3	4	4	4	5	5	5

Design 30
Dimensions (mm)

	Enclosure Size					
	2	3	4	5	6	7
Height	240	240	240	240	240	240
Width	149	221	293	364	400	472
Depth	102.5	102.5	102.5	102.5	102.5	102.5

Design 30 Dual Row
Dimensions (mm)

	Enclosure Size					
	3 (2)	4 (2)	5 (2)	6 (2)	7 (2)	
Height	480	480	480	480	480	
Width	221	293	364	400	472	
Depth	102.5	102.5	102.5	102.5	102.5	

ZD0820



Number of Knockouts						
☐ Top Face 30 x 25	2	2	2	2	2	2
☐ Top Face 40 x 30	0	2	4	4	6	6
☐ Back 100 x 50	1	1	1	3	3	3
☐ Bottom Face 30 x 25	2	3	4	4	5	5

Number of Knockouts						
2	2	2	2	2	2	2
2	4	4	4	6	6	6
2	2	6	6	6	6	6
3	4	4	4	5	5	5

Note: Only BASEC approved cable should be used 1.0mm² to 16mm² for outgoing cables

Up to 35.0mm² for incoming live cables. Single conductors below 1.5mm² need to be doubled back in the terminal bar.

✓ Included with board
* Knockouts available by choice on Design 30 range. References ending with a 'K' contain knockouts.
● Available as an accessory

Accessories Comparison
Surface Mounted Consumer Units

Feature	Description	Design 10	Design 30
Meter tail entry plate (VM04CE)	When clipped into place, the moulding holes allows meter tails and CPC to enter the board safely	✓	✓
Top wall cable entry plates (VM03CE)	Specially designed for our square knockouts, these plates provide more secure cable entry when used with 50x50mm trunking, IP ratings can be achieved	✗	✗
Blind cable entry plates (VM04CB, VM03CB)	A blank plate for drilling which allows the installer to decide on the method of incoming cables - compression gland etc.	✗	✗
Rear cable entry plate (VM02CE)	Allows cables to enter the rear of the board without the risk of damage from sharp edges.	✗	✓
Cable clamp (VA10MT)	Incoming meter tails can be safely secured, eliminating stress within the switch terminal.	✗	✓
Stand-off plate (VM01SF)	Provides 12mm of clearance at the rear of the consumer unit to allow surface mounted cables to enter the board from the rear.	✗	✗


Guidance Notes:

The total load must not exceed the rating of the incoming device or the assigned assembly rating (InA) whichever is the lower. Each neutral and earth connection must correspond numerically to its outgoing way. Additional blanks (ref. JK01B) are available to cover spare ways.

A pack is provided to label this consumer unit, please consult us for spares or replacements.

Operating instruction leaflet is provided overleaf. This leaflet should be left for the end user.


Single conductors below 1.5mm² need to be doubled back in the terminal bar (PCB delayed) RCDs, e.g. 100 mA s-type RCDs. Alternatively a main switch with RCD (as per BS7671 regulation §31.4.1)




Fitting Hager MCBs and RCBs:

Only equipment and arrangements specified in Hager's technical documentation / catalogue shall be used.

1. Isolate the electrical supply from the consumer unit.
2. Remove the front cover, by loosening the two captive screws.
3. Fully slacken the lower terminal of the device.
4. Fully open the bottom device clip (fig 1.)
5. Locate the device onto the din rail, and busbar. Ensure that the busbar tooth is within the device terminal cage.
6. Close the bottom device clip.
7. While holding the device firmly onto the busbar, fully tighten the lower terminal screw.
8. After fitting all outgoing devices and connecting all outgoing cables, please check the tightness of all cable connections. This should include all factory made connections, which may have loosened during installation or transit.



For boards with Surge Protection fitted (References ending in SPD)



Where surge protective devices (SPDs) or other equipment are likely to influence the verification test, or be damaged, such equipment shall be disconnected before carrying out the insulation resistance test.

Cable Access:

Cable access into the metal consumer unit must maintain the integrity of the non-combustible consumer unit so far as reasonably practicable. This can generally be achieved by the installer ensuring that cable access holes they make in the enclosure do not to leave gaps greater than:

- 1.0 mm for the horizontal top surface and
- 2.5 mm for all other surfaces of the enclosure that are accessible after installation.

For rear cable access, the minimum number of knockouts(s) shall be removed.

Tests on hager consumer units have indicated that there is no specific need for external fire rated cable glands or infumescant sealing in addition to the guidance below. However, if the installer wishes to provide additional protection, they should not preclude the design/installer from using the rated cable glands or external infumescant sealing should they consider necessary. Internal infumescant pads shall not be used.

Selection of RCDs

Different types of RCD exist, depending on their behaviour in the presence of DC components and frequencies.

Overload protection of switches and RCCBs

This can be achieved by:

Method 1

Ensure the sum of the rated current of the downstream MCBs do not exceed the rated current of the switch or RCCB (I_{nc}). This method would however need to consider the consequences of any spare ways and later additions.

Method 2

Ensure that the rated current of a switch or RCCB (I_{nc}) stated by the assembly manufacturer is not less than the rating of the upstream OCPD. For a domestic installation this could be a 100A cut-out fuse.

Method 3

Select a consumer unit or distribution assembly that only utilises RCCBs on outgoing circuits. Consideration will still need to be given as to the rated current of the main switch.

For more information on these subjects we have made the relevant BEAMA guides available on our 18th edition hub on our website at hager.co.uk/18thedition

Warranty

This distribution board is offered with a 24 month warranty against defective material or manufacture. If a warranty claim is necessary, please call the technical support number given at the bottom of the page and we will be pleased to help.

For dimensional information and weights please consult the Hager catalogue.

Torque Settings

Consumer unit terminals	Pz No.	(mm)	Cables >1.5mm ²		Cables ≤1.5mm ²		Cable Stripping (mm)
			Tightening torque (N.m)	Multi Cables	Tightening torque (N.m)	Multi Cable	
Earth and neutral terminal bars	2	6.5	2		1.5		10
Isolation							
Switch Disconnectors / Surge	2	6.5	3.6		3.6		15
Circuit protection							
MCB	2	6.5	2.8		2.8		13
RCCB	2	5.5	2.1		2.1		13
RCCB	2	5.5	2.8		2.8		13
AFDD	2	2	2.1		2.1		13

ZD0820

Interface characteristics	
Rated & operational voltage (Un / Ue)	
230V a.c. 50Hz	
Rated insulation voltage (Ui)	
320V a.c. 50Hz	
Rated impulse withstand voltage (Uimp)	
4kV	
Rated current of the Assembly (InA)	
100A, 63A, 40A, 80A - (VMM/VML933H)	
Note: Dependent upon rating of main incoming device	
Rated current of an Outgoing circuit (InC)	Rated current of outgoing unit (InO)
MCB 6A - 63A (marked rated current on device) RCCO 6A - 50A (marked rated current on device)	RCCB 40A - 100A (marked rated current on device)
Rated conditional short-circuit current of the ASSEMBLY (Icc)	
Annex ZB: 16 kA rms at 250V, power factor 0.6 with equipment and arrangements specified in Hager's technical documentation / catalogue.	
Protection against electric shock	
Consumer unit shall be installed in an electrical system conforming to the current edition of IEC 60364 / BS 7671	
Rated diversity factor (RDF) / Values of assumed loading	Note: RDF only applies to continuously and simultaneously loaded circuits.
1Way = 1.0 2Way - 3Way = 0.8 4Way - 5Way = 0.7 6Way - 9Way = 0.6 10Way and above = 0.5	In principle, this means adjacent circuit-breakers having a load 'on' time exceeding 30 minutes or where a load not exceeding 30 minutes has an 'off' time less than the 'on' time, will need to have the rated diversity factor applied as indicated.
Rated frequency (fn)	
50 Hz	
Pollution degree	
2	
Types of system earthing for which the ASSEMBLY is designed	
TN-C-S, TN-S, when installed in an electrical installation complying with BS 7671	
Hager recommends for TT systems a 100A type S time delayed RCCB or a main switch with RCCO protection only on all outgoing circuits.	
Indoor use only	
Stationary ASSEMBLY	
Degree of protection	
IP2XC with Door Open / closed and full complement of outgoing devices and or blanks fitted.	
Note: Where cables are installed through top wall of enclosure, gaps of IP4X to be maintained.	
Intended use	
Intended for use in domestic (residential) or similar premises.	
Electromagnetic compatibility (EMC) classification	
EMC Environment B	
External design	
V.M.L.: Wall-mounted, surface type, enclosed assembly.	
Mechanical impact protection	
IK 05	
The type of construction	
Fixed parts	
Type A DBO (Distribution board for use by ordinary persons)	

ZD0820

ZD0820