

Product Code: UDTAKITG

Description: Indication, Pull Cord and Reset Modules for Assistance Alarm Kit



Component 1 Description

UDTAPCMG - Pull Cord Module

Quantity

1

Component 2 Description

UDTAPLBMG - Power, Light and Buzzer Module

Quantity

1

General Information

Dimensions (mm)	87 x 87 x 41
Colour	Grey
Light Reflectance Value (LRV)	32
Pull Cord Length (m)	3 (Including 2 Triangular Bangles)
Plate Size	Single Gang
Materials	Anti-Microbial ABS
Mounting	Surface or Flush (Surface Box Included)
Anti-Ligature	Yes

Supply & Power

Operating Voltage (V DC)	12
Maximum Cable Size (mm ²)	1.5
Power Consumption (W)	0.3

Environment

Ingress Protection	IP20
Storage Temperature (°C)	

General Information

Dimensions (mm)	87 x 87 x 41
Plate Size	Single Gang
Colour	Grey
Light Reflectance Value (LRV)	32
Materials	Anti-Microbial ABS
Mounting	Surface or Flush (Surface Box Included)
Indication	LED illuminates in red when in alarm state
Activated Buzzer Sound Level (db)	>80
Purpose	Activation and Reset Circuits
Maximum Cable Size (mm ²)	1.5
Power Consumption (A)	0.2
Battery Backup	A23 Battery
Input Type	Ground & 2 live circuits - X1 & X2
Activation Type	Energise with a Normally Open Clean Contact
Output Type	1 Switched Live sharing common ground Separate output for additional sounders
Number of Outputs	2
Output Rating	12V 500mA
Ingress Protection	IP20

Component 3 Description

UDTAREMG - Assistance Alarm Reset Module

Quantity

1

General Information

Dimensions (mm)	87 x 87 x 41
Plate Size	Single Gang
Colour	Grey
Light Reflectance Value (LRV)	32
Materials	Anti-Microbial ABS
Mounting	Surface or Flush (Surface Box Included)
Indication	LED illuminates in red when in alarm state
Buzzer Sound Level When Activated (db)	>80
Operating Voltage (V DC)	12
Maximum Cable Size (mm ²)	1.5
Power Consumption (W)	0.9
Ingress Protection	IP20





Product Code: UDTAKITG

Description: Indication, Pull Cord and Reset Modules for Assistance Alarm Kit

Warranty Years 2

Additional Information Part M1 of the Building Regulations refers to the 'Access and Use' of a building and its facilities with Sections 4.25 to 4.29 then refining the use and design considerations of switches, outlets and controls. Beacon grey assistance alarm products work perfectly with these regulations. Part of the requirements of Part M1 is to aid disabled people within their surroundings, being able to activate a light, socket or control within arms length, for the visually impaired being able to identify the units' position against its surrounding décor, and for the infirm a suitable pull-cord switch to raise the alarm in the event of an emergency

Features

Anti-Ligature Red Pull Cord

Accessories

- UDTAPLBMG: Assistance Alarm, Power, Light and Buzzer Module
- UDTALBMG: Assistance Alarm Light and Buzzer Module
- UDTAPCMG: Assistance Alarm Pull Cord Module
- UDTASPC: Assistance Alarm Replacement Pull Cord
- UDTAREMG: Assistance Alarm Reset Module

